

FIRE TEST QUALIFICATION CERTIFICATE



Score (Europe) Ltd



Item	Butterfly Valve
Size	DN80 41101CS & 41001CS
Class	PN 25
Serial no	No Data / Test Direction Flow behind disc
Body material	ASTM A351 CF-8M
Seat	EN10028-7 1.4436
Manufactured by	SENTO OY HOGFORS
In accordance with job number	143435 COW
In accordance with drawing number	2529364a 16/2/00

The above valve was tested by **Score (Europe) Ltd** at their Specialised Valve Research and Test Centre, Cowdenbeath, Scotland and the results have been recorded as a **PASS**, having complied with the minimum performance requirements stated in specification

Test date	03-08-04
Other sizes qualified	DN 80, 100, 125, 150, 3", 4", 5" & 6"
Other pressure ranges qualified	PN25 & PN40, 300#, 400#, & 600#

Tested by **R. Hepburn / W. Hay**
(Score Europe Ltd.)

Witnessed by **W. Campbell - Lloyds**
Register EMEA



This certificate must be read in conjunction with the full
Score Test Report Number

143435-1